



CODE	D (DIAMETER) (mm)	L (LENGTH) (mm)	CAPACITY (LTRS)	CAPACITY (m3)
SUB650D.800	650	2500	800	0.8
SUB650D.900	650	2800	900	0.9
SUB650D.1000	650	3100	1,000	1.0
SUB650D.1100	650	3400	1,100	1.1
SUB650D.1200	650	3700	1,200	1.2
SUB650D.1300	650	4000	1,300	1.3
SUB650D.1400	650	4300	1,400	1.4
SUB650D.1500	650	4600	1,500	1.5
SUB800D.1000	800	2500	1,000	1.0
SUB800D.1100	800	2700	1,100	1.1
SUB800D.1200	800	2900	1,200	1.2
SUB800D.1300	800	3100	1,300	1.3
SUB800D.1400	800	3300	1,400	1.4
SUB800D.1500	800	3500	1,500	1.5
SUB800D.1600	800	3700	1,600	1.6
SUB800D.1700	800	3900	1,700	1.7
SUB800D.1800	800	4100	1,800	1.8
SUB800D.1900	800	4300	1,900	1.9
SUB800D.2000	800	4500	2,000	2.0
SUB1000D.1800	1000	2500	1,800	1.8
SUB1000D.2000	1000	2750	2,000	2.0
SUB1000D.2200	1000	3000	2,200	2.2
SUB1000D.2400	1000	3250	2,400	2.4
SUB1000D.2600	1000	3500	2,600	2.6
SUB1000D.2800	1000	3750	2,800	2.8
SUB1000D.3000	1000	4000	3,000	3.0
SUB1000D.3200	1000	4250	3,200	3.2
SUB1000D.3400	1000	4500	3,400	3.4

CODE	DESCRIPTION
<b>STANDARD FEATURES</b>	
	Polythylene Tank C/W Riser
	500mm Lid
	Lifting Points
	100mm Overflow C/W Wallace Seal
	100mm Discharge C/W Wallace Seal (excluding Orifice)*
<b>Optional Features</b>	
XXXX	Sediment Trap/Pump Recess
XXXX	Leaf Filter**

\*To install the orifice drill the required hole using a hole saw into a 100mm PVC cap (Marley Part No 137-100) and fit to end of discharge pipe on inside of tank.  
 \*\*Leaf Filter is to prevent any risk of the orifice becoming blocked. Comes complete with one preinstalled 100mm inlet.

NAME	DATE	<b>Bailey Tanks Limited</b> 36 Ash Road, Wiri, Auckland, New Zealand Tel: + 64 9 2627070 Fax: +64 9 2627071 Web: www.baileytanks.com Email: info@baileytanks.com		
DRAWN	D.I.B.			06 May 2011
CHK'D				
APP'VD				
DIMENSIONS OF ROTO MOULDED PARTS ARE APPROX DUE TO VARIATIONS IN THE MANUFACTURING PROCESS			DWG NO. <b>SWR16052011</b>	
DO NOT SCALE DRAWING Copyright Bailey Tanks Limited 2011				
WEIGHT:	SCALE: 1:25	SHEET 1 OF 1	REVISION	

